

STATE OF CALIFORNIA
WELL COMPLETION REPORT
Refer to Instruction Pamphlet

DWR USE ONLY --- DO NOT FILL IN

STATE WELL NO./STATION NO.

LATITUDE LONGITUDE

APN/TRS/OTHER

Page 1 of 1

Owner's Well No. Well #3

No. **E047407**

Date Work Began 12/29/2006, Ended 12/29/2006

Local Permit Agency San Luis Obispo County

Permit No. 2006-370

Permit Date 12/12/2006

GEOLOGIC LOG

ORIENTATION (✓) VERTICAL HORIZONTAL ANGLE _____ (SPECIFY)

DEPTH FROM SURFACE
Fl. to Fl.

DRILLING METHOD ROTARY FLUID Air

DESCRIPTION
Describe material, grain, size, color, etc.

0	3	TOP SOIL
3	147	BROWN CLAY
147	230	BLUE SHALE
230	310	BLUE SHALE GRAVELS
310	320	GREEN SHALE

The Air Lift Test is only approximate. A Test Pump is recommended for an accurate account. (WP)


WELL OWNER

Name Kiler Canyon Partners
Mailing Address 200 Crestmont Drive
San Luis Obispo CA 93401
CITY STATE ZIP

WELL LOCATION

Address Kiler Canyon Road - Well #3
City Paso Robles CA
County San Luis Obispo
APN Book 018 Page 221 Parcel 003
Township 27 S Range 12 E Section 5
Latitude 385 36 504 N 120 42 106 W
DEG. MIN. SEC. DEG. MIN. SEC.

LOCATION SKETCH



- ACTIVITY (✓)
- NEW WELL
 - MODIFICATION/REPAIR
 - Deepen
 - Other (Specify)
 - DESTROY (Describe Procedures and Materials Under "GEOLOGIC LOG")
 - PLANNED USES (✓)
 - WATER SUPPLY
 - Domestic Public
 - Irrigation Industrial
 - MONITORING
 - TEST WELL
 - CATHODIC PROTECTION
 - HEAT EXCHANGE
 - DIRECT PUSH
 - INJECTION
 - VAPOR EXTRACTION
 - SPARGING
 - REMEDIATION
 - OTHER (SPECIFY)

Illustrate or Describe Distance of Well from Roads, Buildings, Fences, Rivers, etc. and attach a map. Use additional paper if necessary. PLEASE BE ACCURATE & COMPLETE.

WATER LEVEL & YIELD OF COMPLETED WELL

DEPTH TO FIRST WATER _____ (Ft.) BELOW SURFACE 1

DEPTH OF STATIC WATER LEVEL 150 (Ft.) & DATE MEASURED 12/29/2006

ESTIMATED YIELD 75 (GPM) & TEST TYPE Air Lift

TEST LENGTH 1 (Hrs.) TOTAL DRAWDOWN _____ (Ft.)

May not be representative of a well's long-term yield.

TOTAL DEPTH OF BORING 320 (Feet)

TOTAL DEPTH OF COMPLETED WELL 320 (Feet)

DEPTH FROM SURFACE Fl. to Fl.	BORE-HOLE DIA. (Inches)	CASING (S)							
		TYPE (✓)				MATERIAL / GRADE	INTERNAL DIAMETER (Inches)	GAUGE OR WALL THICKNESS	SLOT SIZE IF ANY (Inches)
BLANK	SCREEN	CON-DUCTOR	FILL PIPE						
0 to 260	10	✓				F-480 PVC	5	SDR 21	
260 to 320	10		PERF			F-480 PVC	5	SDR 21	.040

DEPTH FROM SURFACE Fl. to Fl.	ANNULAR MATERIAL TYPE			
	CE-MENT (✓)	BEN-TONITE (✓)	FILL (✓)	FILTER PACK (TYPE/SIZE)
0 to 52	✓			
52 to 320			✓	Monterey Mix

ATTACHMENTS (✓)

- Geologic Log
- Well Construction Diagram
- Geophysical Log(s)
- Soil/Water Chemical Analysis
- Other _____

ATTACH ADDITIONAL INFORMATION, IF IT EXISTS.

CERTIFICATION STATEMENT

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.

NAME FILIPPONI & THOMPSON DRILLING

(PERSON, FIRM, OR CORPORATION) (TYPED OR PRINTED)

P.O. BOX 845

ATASCADERO

CA

93423

ADDRESS

CITY

STATE

ZIP

Signed

[Signature]

01/09/07

DATE SIGNED

432680

WELL DRILLER/AUTHORIZED REPRESENTATIVE

C-57 LICENSE NUMBER

WELL PERMIT PLOT PLAN

SAN LUIS OBISPO COUNTY ENVIRONMENTAL HEALTH SERVICES
2156 Sierra Way
San Luis Obispo, California 93401
Telephone: 805-781-5544

(Butterfield) Kiler Canyon Ptrs.

SCALE: 1/4" = 25'

INDICATE BELOW THE **EXACT LOCATION** OF PROPOSED WELL WITH RESPECT TO THE FOLLOWING ITEMS: PROPERTY LINES, WATER BODIES OR WATER COURSES, DRAINAGE PATTERN, ROADS, EXISTING WELLS, SEWERS AND PRIVATE SEWAGE DISPOSAL SYSTEMS AND ANY OTHER CONCENTRATED SOURCES OF POLLUTION. **INCLUDE DIMENSIONS.** ALL PROPOSED WELL SITES SHALL BE DESIGNATED WITH A FLAGGED SURVEYOR'S STAKE LABELED "WELL SITE." DRILLING SHALL NOT COMMENCE UNTIL THIS APPLICATION IS APPROVED.

